



- SEE DRAWING 1705-303  
(NON/BARN DOOR END)



ELECTRICITY IS DANGEROUS

GENERAL

IT IS UNDERSTOOD THAT A COMPETENT CONTRACTOR FAMILIAR WITH THE WORKS REQUIRED WILL BE APPOINTED AND THAT THEY WILL BE AWARE OF THE STANDARD HAZARDS.

DO NOT SCALE FROM THIS DRAWING.  
WORK FROM FIGURED DIMENSIONS ONLY.  
ALL DIMENSIONS ARE IN MM, UNLESS  
STATED OTHERWISE.  
ALL DIMENSIONS TO BE CHECKED ON  
CONTRACTOR TO CONSTRUCTION OR  
ORDERING.  
ANY ERRORS OR OMISSIONS TO BE  
NOTIFIED TO CITIZEN LIMITED  
IMMEDIATELY.  
CONTRACTOR TO READ & CHECK ALL  
MATERIALS, MANUFACTURE AND  
IMPLEMENT ITS REQUIREMENTS PRIOR TO  
INSTALLATION OF ANY MATERIALS AND  
COMPONENTS.  
CITIZEN LIMITED IS NOT RESPONSIBLE  
FOR ANY BUILDING WORK THAT IS  
CARRIED OUT ON SITE.  
ALL DRAWINGS ARE TO BE READ IN  
CONJUNCTION WITH ALL NECESSARY  
ARCHITECTURAL, STRUCTURAL AND  
MECHANICAL SPECIFICATIONS, CONDITIONS,  
SCOPES OF WORK & ROOM DATA SHEETS.  
ALL MATERIALS AND WORKMANSHIP  
TO BE CONFORMED TO THE MOST RELEVANT  
BRITISH AND EUROPEAN STANDARD,  
SPECIFICATIONS AND CODES OF  
PRACTICE.  
IF IN ANY DOUBT, ASK.

- CABLE HOLES THROUGH ISOWALL PANELS TO BE SEALED & GASKETED TO AVOID CHAFFING.  
CABLES TO BE 6181Y PVC INSULATED SINGLES FOR LOW TEMPERATURES WITH ALL CORES IDENTIFIED AND GASKETED. CABLES MUST BE INSTALLED ABOVE 0°C (BUT OPERATING RANGE DOWN TO -15°C) ALL OUTLETS TO BE FLUSH MOUNTED, AND TO BE ORIGINAL OR APPROVED BY ETC. AND PART P COMPLIANT C/W CERTIFICATION AND SIGN OFFS.  
ALL OUTLETS TO BE PROPERLY MARKED. ALL PENETRATIONS, PERFORATIONS, CABLES, PIPES AND DUCTS TO BE PROVIDED WITH FIRE COLLARS & SLEEVES.  
SEE DRAWING FOR DETAILS AND FOR THE TYPICAL SERVICES INTERNAL CUPBOARD.

COPYRIGHT CITYZEN LIMITED

1 705-231 (I)